

G E BRIGHT ELECTRICAL

Customer Name: Mr Thorpe

Address: 7 Woodston Oast House
Eardiston, Worcs, WR15 8JG

Serial Number:

Date of Test: 25th January 2011

Test Engineer: J. Cole

| APPLIANCE | ID | CLASS | VISUAL | EARTH CONTINUITY | FUSE CURRENT TEST (A) | INSULATION | RUN TEST | PASS/ FAIL |
|--|----|-------|--------|------------------|-----------------------|------------|----------|------------|
| 6 GANG SURGE PROTECTION EXTENSION LEAD | 1 | 1 | PASS | 0.05 | 0.0 | 0.8 | 0.0 | PASS |
| DS80 PRINTER | 2 | 1 | PASS | 0.07 | 0.0 | 19.9 | 0.0 | PASS |
| 3 CORE LEAD | 3 | 1 | PASS | 0.06 | 0.0 | 19.9 | 0.0 | PASS |
| DS40 PRINTER | 4 | 1 | PASS | 0.07 | 0.0 | 19.9 | 0.0 | PASS |
| 3 CORE LEAD | 5 | 1 | PASS | 0.06 | 0.0 | 19.9 | 0.0 | PASS |
| SAMSUNG LAPTOP POWER SUPPLY | 6 | 2 | PASS | - | 0.0 | 19.9 | 0.0 | PASS |
| 3 CORE LEAD | 7 | 1 | PASS | 0.04 | 0.0 | 19.9 | 0.0 | PASS |
| USB HUB | 8 | 2 | PASS | - | 0.02 | 19.9 | 0.0 | PASS |
| D-LINK ROUTER | 9 | 2 | PASS | - | 0.0 | 19.9 | 0.0 | PASS |
| 8 GANG EXTENSION LEAD | 10 | 1 | PASS | 0.05 | 0.0 | 0.8 | 0.0 | PASS |
| 6 GANG SURGE PROTECTION EXTENSION LEAD | 11 | 1 | PASS | 0.05 | 0.0 | 0.8 | 0.0 | PASS |
| 3 CORE LEAD | 12 | 1 | PASS | 0.12 | 0.0 | 19.9 | 0.0 | PASS |
| ESPRIT LIGHT | 13 | 1 | PASS | 0.12 | 0.1 | 19.9 | 0.12 | PASS |
| GM500 LIGHT | 14 | 1 | PASS | 0.13 | 0.0 | 19.9 | 0.18 | PASS |

G E BRIGHT ELECTRICAL

Customer Name: Mr Thorpe

Address: 7 Woodston Oast House
Eardiston, Worcs, WR15 8JG

Serial Number:

Date of Test: 25th January 2011

Test Engineer: J. Cole

| APPLIANCE | ID | CLASS | VISUAL | EARTH CONTINUITY | FUSE CURRENT TEST (A) | INSULATION | RUN TEST | PASS/ FAIL |
|------------------|----|-------|--------|------------------|-----------------------|------------|----------|------------|
| 3 CORE LEAD | 15 | 1 | PASS | 0.13 | 0.0 | 19.9 | 0.0 | PASS |
| GM500 LIGHT | 16 | 1 | PASS | 0.13 | 0.0 | 19.9 | 0.1 | PASS |
| 3 CORE LEAD | 17 | 1 | PASS | 0.13 | 0.0 | 19.9 | 0.0 | PASS |
| 3 CORE LEAD | 18 | 1 | PASS | 0.21 | 0.0 | 19.9 | 0.0 | PASS |
| 3 CORE LEAD | 19 | 1 | PASS | 0.06 | 0.0 | 19.9 | 0.0 | PASS |
| TOPVIEW MONITOR | 20 | 1 | PASS | 0.05 | 0.0 | 19.9 | 0.01 | PASS |
| TOPVIEW MONITOR | 21 | 1 | PASS | 0.06 | 0.0 | 19.9 | 0.04 | PASS |
| 3 CORE LEAD | 22 | 1 | PASS | 0.06 | 0.0 | 19.9 | 0.0 | PASS |
| 3 CORE LEAD | 23 | 1 | PASS | 0.06 | 0.0 | 19.9 | 0.0 | PASS |
| TOP VIEW MONITOR | 24 | 1 | PASS | 0.06 | 0.0 | 19.9 | 0.05 | PASS |
| TOP VIEW MONITOR | 25 | 1 | PASS | 0.07 | 0.0 | 19.9 | 0.03 | PASS |
| 3 CORE LEAD | 26 | 1 | PASS | 0.07 | 0.0 | 19.9 | 0.0 | PASS |
| 3 CORE LEAD | 27 | 1 | PASS | 0.06 | 0.0 | 19.9 | 0.0 | PASS |
| TOP VIEW MONITOR | 28 | 1 | PASS | 0.06 | 0.0 | 19.9 | 0.05 | PASS |